



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA200856

Date of Issue: 16 June 2020

Regulatory Definition: Non-Prescribed
Product Description: Isolator Switch

General Modification:

For 040.000.0252:
4-pole (3P+N)

Additional Models	Trade Name	Rating/Marking	Description
040.000.0228	4Cabling	250Vac 50Hz 20A IP66, M180, AC-22A	1-pole (1P)
040.000.0229	4Cabling	250Vac 50Hz 35A IP66, M180, AC-22A	1-pole (1P)
040.000.0230	4Cabling	250Vac 50Hz 20A IP66, M180, AC-22A	2-pole (2P)
040.000.0231	4Cabling	250Vac 50Hz 35A IP66, M180, AC-22A	2-pole (2P)
040.000.0232	4Cabling	440Vac 50Hz 20A IP66, M180, AC-22A	3-pole (3P)
040.000.0233	4Cabling	440Vac 50Hz 35A IP66, M180, AC-22A	3-pole (3P)
040.000.0234	4Cabling	440Vac 50Hz 63A IP66, M180, AC-22A	3-pole (3P)
040.000.0248	4Cabling	250Vac 50Hz 63A IP66, M180, AC-22A	1-pole (1P)
040.000.0249	4Cabling	250Vac 50Hz 63A IP66, M180, AC-22A	2-pole (2P)
040.000.0250	4Cabling	440Vac 50Hz 20A IP66, M180, AC-22A	4-pole (3P+N)
040.000.0251	4Cabling	440Vac 50Hz 35A IP66, M180, AC-22A	4-pole (3P+N)

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd is accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 16-06-20 200856/2