



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA201489

Certificate Holder: 4Cabling Pty Ltd
17/31 Maddox Street
Alexandria NSW 2015
Australia

Regulatory Definition: Non-Declared
Product Description: Weatherproof Surface Socket Outlet
Trade Name: 4Cabling
Model No.: 040.000.0213
Rating / Marking: 500Vac 50A 50Hz
IP66

Standard: AS/NZS 3123:2005
AS/NZS 3100:2017 Inc A1
Conditions: Nil

Certification Mark: SAA201489 or RCM

Date First Registered: 20 July 2020
Date of Expiry: 20 July 2025

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd confirms that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au



Issued: 20-07-20 201489/1